



**OFFICE OF THE DEPUTY FIRE OFFICER
BALASORE CIRCLE, BALASORE**

BY MAIL

L. No-400/BLS.CLE

Dt- 11.03.2022

To

The Principal, Kendriya Vidyalaya,
Laxmiposi, Baripada,
Dist-Mayurbhanj



Ref:- Your Letter No-318/ dtd-03.03.2022

Sub:- Issuance of Fire Safety Certificate of the school Building for K.V-1 on urgent basis.

Sir,

With reference to the above cited subject and reference above, this is to intimate that the undersigned officer with a team of Officers were visited your school Building on 08.10.2021 as Chief Fire Officer (SAG), Fire prevention wing, got permitted for your offline application and requested to comply the shortfalls on same day vide L. No-2045/BLS CLE dtd-08.10.2021 for further action at this end. Besides your were requested to apply for issuance of Fire safety certificate of your building through online mode (www.agnishamaseva.gov.in) in form -III along with self attested copies of documents as mentioned in form-III and required fees @ Rs-2/- per square meter of total built up area in respect of your school in government account through e-challan vide L. No-2016/B:S CLE dtd-25.09.2021 and offline application has not been entertained as this end as per the higher quarter. But as per request vide L. No-198 dd-22.09.2021 along with Form-III and original treasury challan with necessary documents, the undersigned has got permitted from Chief Fire Officer, SAG and batch

Now, you are requested vide Letter No-318/ dtd-03.03.2022 and mentioned that your school building is a two storied building & having height less than 09 mtrs is self regulatory and provided nos of Extinguishers.

As per Govt. Notification No-10573/Home BBSR , dtd-06.03.2019 in OFP & OFS rule 2017 r/w OFP & FS (Amendment) in Rule-2019 (j) an Educational Building having a built up area of 1000 sqr meter or above likely to have risk of fire comes in ambit of the Rules for issuance of Fire safety certificate.

Hence, your requested to adopt fire fighting gadgets as per requirement of NBCI-2016 for issuance of Fire safety Certificate in favour of school Building.

This is for favour of your kind information and necessary action please

Yours Faithfully

11/03/2022

(Satyapir Behera)
Deputy Fire Officer
Balasore Circle, Balasore

Memo No- /BLS CLE

Date- . 03.2022

Copy submitted to AFO Baripada FS / Collector-cum- chairman , VMC , KV Baripada for kind information

(Satyapir Behera)
Deputy Fire Officer
Balasore Circle, Balasore