

## ANALYTICAL TEST REPORT OF WATER SAMPLES

Sl.no	Source & Location	Date of Collection	Date of Testing	Name of parameters (With units)						Remarks
				pH (permissible limit-6.5--8.5)	Hardness as CaCO <sub>3</sub> , mg/l (permissible limit--600.00 mg/l)	Chloride, mg/l (permissible limit--1000.0 mg/l)	Iron, mg/l (permissible limit--0.3 mg/l)	Residual Chlorine, mg/l (permissible limit--0.2 mg/l)	Bact. Test by H <sub>2</sub> S Strip	
1	2	3	4	6	7	8	9	10	11	12
1	Kendriya Vidyalaya, Laxmiposi, Baripada.	22/10/2016	24/10/2015	7.18	76.00	24.00	0.29	0.0	0	

N.B.-- a) Water is safe.

- b) Adequate Chlorination is required to maintain minimum standard of Residual Chlorine.  
 c) Water Storage Tank should be cleaned periodically.

*K. Kallip*  
 24/10/16  
 Junior Laboratory Assistant  
 Dist. Level Laboratory, Baripada.

*R.S.S.*  
 24/10/16  
 Asst. Executive Engineer,  
 R.W.S. & S. Sub Division No-I, Baripada.

*[Signature]*  
 Executive Engineer  
 R.W.S. & S. Divn.  
 BARIPADA